



ELEVATION

SECTION A-A

*NOTE: WHERE A WATER MAIN PASSES BENEATH AND WITHIN 18" OF A SANITARY SEWER MAIN, THE WATER MAIN SHALL BE ENCASED IN CONCRETE 10 FEET EACH SIDE OF THE SEWER MAIN.

CITY OF CRIPPLE CREEK WATER DEPARTMENT	
ENCASEMENT DETAIL	
DESIGNED BY L. OTTO	DATE 12/83
APPROVED BY	DATE
SCALE NONE	
REVISED BY ADD, IT	DATE 4/84
	18