

<u>Type of Establishment</u>	<u>Device Required</u>
Stock Yard	R/P
Transportation terminal	R/P
Veterinary	R/P

NOTE: Other types of establishments may require protection via air gaps or backflow prevention devices depending on the equipment and/or plumbing arrangements utilized therein. These shall be considered individually, at the discretion of the City of Cripple Creek. All of the establishments listed below will require review by the City and a determination made as to the need for a backflow prevention device.

Apartments and condominiums - single and multi-structures - four units or more, three stories or less

Barber shop or college

Beauty shop or college

Buildings - three stories or less

Cafeteria, restaurant, coffee shop, etc. (any food handling establishment)

Department store

Hotels and motels - single structures and multi-structures, three stories or less

Laundromat

Office or Warehouse