



PIPE DIAMETER	MINIMUM WIDTH	MAXIMUM WIDTH
4"	1'-5"	2'-5"
6"	1'-7"	2'-7"
8"	1'-9"	2'-9"
12"	2'-1"	3'-1"
16"	2'-6"	3'-6"
20"	2'-10"	3'-10"
24"	3'-2"	4'-2"
36"	4'-2"	5'-2"

AN OVER EXCAVATED TRENCH SHALL BE REFILLED AND THOROUGHLY COMPACTED UNDER THE DIRECTION OF THE DEPT. OF PUBLIC WORKS.

UNDER NO CIRCUMSTANCES WILL PIPE BE LAID IN A PROPOSED FILL AREA PRIOR TO IT BEING COMPLETELY FILLED. THE FILL WILL BE PLACED FIRST TO PROPOSED GRADE AND COMPACTED AS REQUIRED. A TRENCH THEN WILL BE EXCAVATED AND THE PIPE INSTALLED IN THE USUAL MANNER.

**CITY OF CRIPPLE CREEK**  
WATER DEPARTMENT

TRENCH CROSS SECTION

DRAWN BY: B. MAC

APPROVED BY:

DATE:

REVISIONS:

BY: