



Cripple Creek Fire Department

147 E. Bennett Avenue

PO Box 430

Cripple Creek, Colorado 80813

719-689-0240

EXITS	✓
Stairs have one (1) graspable hand-rail	
No storage of flammable/combustibles on, in, or under exits or escape paths	
Stair/Landing surface free of trip hazards	
Exits/Escapes require no key or tool from inside to open	
Each sleeping area has one (1) secondary means of escape with a clear opening measuring at least 5.7 square feet	
Posted floor diagram showing primary exit and secondary escape	
Stair width clear of obstructions **Minimum recommended width: 36 inches**	
ALERTING	✓
Hardwired smoke detectors in every bedroom	
Hardwired smoke detectors outside of every bedroom or group of bedrooms	
Hardwired smoke detectors in common areas and throughout all levels **Placement in garages and kitchens, not required**	
(1) CO detector per floor	
Battery powered smoke detectors test log available **Tested weekly**	
ELECTRICAL SAFETY	✓
Breakers/Fuses are labeled	
No exposed electrical wiring	
No “daisy chain” of extension cords or powerstrips	
Extension cords are in good condition; No signs of wear or damage ; Temporary use only	
PROTECTION	✓
Fire extinguisher, minimum size 2A:10BC (requires a current state inspection tag from a licensed contractor)	
Dryer vent clear of lint	
No excessive storage of combustible or flammable material	
LP/Gas tanks are in good condition and within hydrostatic test date	

Date: ____/____/____

On-Site Evaluation Conducted by: _____